



Product Service

# CERTIFICATE

No. Z2 002614 0008 Rev. 04

**Holder of Certificate:** **Anhui Tunghsu Kangtu Solar Technology Co., Ltd.**  
Meishan Lake Road, Modern Industrial Park, Jinzhai County  
237300 Lu'an City, Anhui Province  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 882161908905

**Valid until:** 2026-07-01

**Date,** 2021-12-14

( Xinlian LUO )

# CERTIFICATE

No. Z2 002614 0008 Rev. 04

**Model(s):**

**1000V DC Module**

- DXM60-Z5-xxx (xxx=280-345, in step of 5)
- DXM72-Z5-xxx (xxx=330-405, in step of 5)
- DXM60-B5-xxx (xxx=320-360, in step of 5)
- DXM72-B5-xxx (xxx=380-415, in step of 5)
- DXM60-B6-xxx (xxx=360-380, in step of 5)
- DXM72-B6-xxx (xxx=430-455, in step of 5)
- DXM60-DTB5-xxx (xxx=320-350, in step of 5)
- DXM60-DTB6-xxx (xxx=345-380, in step of 5)
- DXM60-DGB5-xxx (xxx=320-350, in step of 5)
- DXM60-DGB6-xxx (xxx=345-380, in step of 5)
- DXM72-DTB5-xxx (xxx=390-420, in step of 5)
- DXM72-DTB6-xxx (xxx=415-455, in step of 5)
- DXM72-DGB5-xxx (xxx=390-420, in step of 5)
- DXM72-DGB6-xxx (xxx=415-455, in step of 5)

**1500V DC Module**

- DXMH60-Z5-xxx (xxx=280-345, in step of 5)
- DXMH72-Z5-xxx (xxx=330-405, in step of 5)
- DXMH60-B5-xxx (xxx=320-360, in step of 5)
- DXMH72-B5-xxx (xxx=380-415, in step of 5)
- DXMH60-B6-xxx (xxx=360-380, in step of 5)
- DXMH72-B6-xxx (xxx=430-455, in step of 5)
- DXMH60-DTB5-xxx (xxx=320-350, in step of 5)
- DXMH60-DTB6-xxx (xxx=345-380, in step of 5)
- DXMH60-DGB5-xxx (xxx=320-350, in step of 5)
- DXMH60-DGB6-xxx (xxx=345-380, in step of 5)
- DXMH72-DTB5-xxx (xxx=390-420, in step of 5)
- DXMH72-DTB6-xxx (xxx=415-455, in step of 5)
- DXMH72-DGB5-xxx (xxx=390-420, in step of 5)
- DXMH72-DGB6-xxx (xxx=415-455, in step of 5)
- DXMH54-B8-xxx (xxx=390-415, in step of 5)
- DXMH60-B8-xxx (xxx=440-465, in step of 5)
- DXMH72-B8-xxx (xxx=525-550, in step of 5)
- DXMH60-BX-xxx (xxx=580-605, in step of 5)
- DXMH50-BX-xxx (xxx=480-505, in step of 5)
- DXMH54-DGB8-xxx (xxx=395-420, in step of 5)
- DXMH60-DGB8-xxx (xxx=445-470, in step of 5)
- DXMH72-DGB8-xxx (xxx=530-555, in step of 5)
- DXMH60-DGBX-xxx (xxx=580-605, in step of 5)
- DXMH50-DGBX-xxx (xxx=480-505, in step of 5)

xxx is standing for rated output power at STC

**Parameters:**

Construction: Framed, with Junction box, Cable and Connectors.  
 Test Laboratory: Yangzhou Opto-electrical product testing institute  
 (10 Kaifa West Rd., Yangzhou, Jiangsu, P. R. China 225009)  
 Safety Class: Class II



# CERTIFICATE

No. Z2 002614 0008 Rev. 04

Maximum System Voltage: 1500V DC or 1000V DC  
Fire Safety Class: Class C according to UL790

**Tested  
according to:**

IEC 61215-1:2016  
IEC 61215-1-1:2016  
IEC 61215-2:2016  
IEC 61730-1:2016  
IEC 61730-2:2016  
EN 61215-1:2016  
EN 61215-1-1:2016  
EN 61215-2:2017  
EN IEC 61730-1:2018  
EN IEC 61730-2:2018  
EN IEC 61730-1:2018/AC:2018-06  
EN IEC 61730-2:2018/AC:2018-06